

Certificate of Performance

On this date the cleanroom facilities of

Oliver Healthcare Packaging Building 2

915 Pennsylvania Boulevard

Feasterville, PA 19053

*Have been tested in accordance with NEBB Procedural Standards for
Certified Testing of Cleanrooms to meet the following air cleanliness classification
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μ m – At-Rest

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μ m – Operational

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μ m – At-Rest

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μ m – Operational

*NEBB Certified Firm: **Air Filtration Management, Inc.***

*Phone: **(610) 867-3869***

www.airfiltrationmgmt.com

*NEBB Certification Number: **3898***

*NEBB CPT Professional: **Michael J. Kelly***

Signature: 

*Test Date: **June 2025** Retest Date: **June 2026***

National Environmental Balancing Bureau

