

# AERO-DYNAMIEK

Oliver Healthcare Packaging  
Spurkt 1  
5804 AR Venray

*Cleanroom 2 is compliant with:*

- **NEN-EN-ISO 14644-1: 2016**
- **ISO Class 7 at-rest**
- **ISO Class 8 operational**

*The performed measurements:*

- Are according to NEN-EN-ISO 14644:1-2016
- Are according to NEN-EN-ISO 14644:3-2019
- Are executed by certified engineers
- Are stated in report QAN0001776

*All validations executed on the 17<sup>th</sup> of January 2025  
Certificate expires: 17<sup>th</sup> of January 2026*

Validation Company:

Aero-Dynamiek b.v.  
Databankweg 7  
3821 AL Amersfoort

J. Volkerink,  
Validation Engineer.

# CERTIFICATE